



Janet T. Mills
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Bruce A. Van Note
COMMISSIONER

December 9, 2019
Subject: Wagner Number Two Bridge
Replacement
State WIN: 018230.00
Location: **Waldoboro**
Amendment No. 1

Dear Sir/Ms:

The following questions have been received:

Question: On page 19 of the plan set on the "Box Section" detail the limits of structural excavation are shown as a dashed line under the box. How will the excavation from that point to bearing subgrade be paid for? And will the limits on that excavation be limited to the granular borrow limits of 1.5' outside of the box as well?

Response: The work described in the question will be paid for under Item No. 206.061, Structural Earth Excavation – Drainage Minor Structures Below Grade. The limits of this item, as defined in the Standard Specifications and the plan set, will be from a depth 1'-0" below the structure until glacial till is encountered, by the plan area of the granular borrow limits as shown. All other excavation will be as required by the Contractor for access, at the cost of the Contractor.

Consider this change and information prior to submitting your bid on **December 11, 2019**.

Sincerely,

George M. A. Macdougall P.E.
Contracts & Specifications Engineer